

28 March 2018

Pl see the annexed

.....  
.....  
.....  
.....  
.....

Dear Sir,

**DESIGN, SUPPLY, INSTALLATION, COMMISSIONING AND OPERATION OF REVERSE OSMOSIS  
PLANT AT BIYAGAMA EXPORT PROCESSING ZONE**

---

**Addendum No. 04**

With reference to the Request for Proposals (RFP) document collected by you in connection with the above, the annexed Addendum No. 04 is also issued with regard the queries made by some of the interested proposers in addition to the Addendum No. 01, 02 & 03 which have already been issued.

Thank you

Yours faithfully

**BOARD OF INVESTMENT OF SRI LANKA**

A.K jayasinghe  
**DIRECTOR (ZONE) BEPZ**

-/gg

**NAME OF PROJECT : DESIGN, SUPPLY, INSTALLATION, COMMISSIONING AND OPERATION OF REVERSE OSMOSIS PLANT AT BIYAGAMA EXPORT PROCESSING ZONE**

**Addendum No. : 04**

<b>Item No</b>	<b>Item/Comments/Decision</b>	<b>Action by</b>	<b>Target date</b>	<b>Out come</b>
1.	<p>Q) Please provide Raw water content on:  <math>Ca^{2+}</math> ; <math>Mg^{2+}</math> ; <math>Na^{+}</math> ; <math>K^{+}</math> ; <math>Ba^{2+}</math> ; <math>Sr^{2+}</math>  <math>HCO_3^{-}</math> ; <math>CO_3^{2-}</math>  <math>Cl^{-}</math> ; <math>SO_4^{2-}</math> ; <math>NO_3^{-}</math> ; <math>F^{-}</math> ; <math>PO_4^{3-}</math> ;  <math>Mn</math> ; <math>B</math> ; <math>Si</math>                      Alkalinity ; Hardness                      Oil (test value)</p> <p>A) The attachment 9.4 which has already been issued to the proposers along with the RFP document shows the tolerance limits of the specified parameters for the discharge of industrial waste water into inland surface waters.</p>			
2.	<p>Q) Please kindly confirm drinking water demand from the reverse osmosis plant, nominated demand and minimum demand.</p> <p>A) Please refer to clause 6.0(ii) of Terms of Reference in section 3 of RFP document. (Page 3.2)</p>			
3.	<p>Q) Please kindly suggest if the Brine from RO and waste water/sludge can be pumped back to centralized waste water treatment plant.</p> <p>A) Brine from RO/waste water/sludge is not allowed to pump back to CWWTP in BEPZ.</p>			
4.	<p>Q) Please kindly provide the AutoCAD drawings for the as mentioned 3 sites for Reverse Osmosis Plant.</p> <p>A) Attached here to</p>			
5.	<p>Q) Please provide topographic information with site elevation for the as mentioned 3 sites for Reverse Osmosis Plant.</p> <p>A) Detailed Topographic information in the proposed sites is not readily available.</p> <p>Interested proposers can be permitted to visit and gather further details of sites.</p>			
6.	<p>Q) Please provide the geological report for the as mentioned 3 sites for Reverse Osmosis Plant.</p> <p>A) Already circulated with Addendum No. 03.</p>			

7.	<p>Q) Please indicate the maximum flooding level if the site can be flooded.</p> <p>A) No previous records of flooding the proposed sites.</p>			
8.	<p>Q) As per Item 9 of Addendum No.2, the proposer's scope of work will be terminated at the treated water storage tank. The following pumping station and pipe network grid shall be excluded from the proposer's scope of work.</p> <p>Please kindly suggest the volume of the treated water storage tank, i.e. 2 hours' storage of daily production flow.</p> <p>A) Volume of treated water storage tank should be determined by the proposer.</p>			
9.	<p>Q) As per item 14 of Addendum No.2, the treated water will be purchased by BOI from the successful proposer. BOI will pay a monthly payment based on the consumption. There will be a minimum guaranteed payment.</p> <p>Please kindly suggest the minimum guaranteed payment.</p> <p>A) No such minimum guaranteed payment has been proposed by BOI.</p>			
10. & 11.	<p>Q) As per Sub Clause 11.4 of Section 2, the submission of the Proposal Security for selected and shortlisted proposer will be informed by the BOI after evaluation of the Technical Proposal. As such, proposers don't need to provide the proposal security with the bidding documents submission.</p> <p>Please kindly confirm.</p> <p>As per item 3 of Section 2 Data Sheet, the amount of Proposal Security is 200,000 LKR to be issued by an Agency acceptable to BOI using from for proposal security.</p> <p>Please kindly provide the list of the Accepted Agencies and confirm the amount of the proposal security.</p> <p>A) Proposal security should be submitted by proposers as specified in the Data sheet - DS No. 04 in section 3 of RFP Document (Page No. 2.14)</p> <p>Proposal security to be furnished by one of the following institutions.</p> <ul style="list-style-type: none"> <li>- by a Bank operating in Sri Lanka, approved by the Central Bank of Sri Lanka</li> </ul>			

	<p>- by an insurance company registered under the Insurance Board of Sri Lanka</p> <p>Proposal security will be returned to the respective proposer after obtaining the performance security from the successful &amp; selected proposer.</p>			
12.	<p>Q) The concession terms for 5 years are too short. Please kindly suggest if the bidder can only propose an offer for a concession period 15 years.</p> <p>A) Please refer to FIN – 4 of financial offer in section 8 (Page No. 8.4) of RFP Document.</p>			
13.	<p>Q) Please kindly suggest the permit should be obtained by proposer to execute the project.</p> <p>A) BOI could issue entry permits in free of charge to successful proposer and his staff to execute project.</p>			
14	<p>Q) Can the deadline for submission the proposals be extended by further period</p> <p>A) The deadline is <b>14.00 hrs on 19.04.2018</b> for submission of proposal and no further extensions please.</p>			

28.03.2018

-/gg